

# TEXAS DEPARTMENT OF INSURANCE

Engineering Services / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104  
Phone No. (512) 322-2212 Fax No. (512) 463-6693

---

## PRODUCT EVALUATION EC-23

Effective April 1, 2004

*The following product has been evaluated for compliance with the wind loads specified in International Residential Code (IRC) and the International Building Code (IBC). This product shall be subject to reevaluation 3 years after the effective date.*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

**Hardipanel<sup>®</sup>, Cempanel<sup>®</sup>, Hardiplank<sup>®</sup>, Complank<sup>®</sup>, Sentry<sup>™</sup>, and Hardishingle<sup>™</sup>**, fiber-reinforced cement exterior siding, and **Hardishingle<sup>™</sup>**, fiber-reinforced cement exterior cladding, manufactured by

**James Hardie Building Products, Inc.**  
**10901 Elm Avenue**  
**Fontana, California 92337**  
**Telephone: 800-426-4051**

will be acceptable for use in designated catastrophe areas along the Texas Gulf Coast when installed in accordance with the manufacturer's installation instructions and this product evaluation.

## PRODUCT DESCRIPTION

The following James Hardie Building Products have been accepted:

**Hardipanel<sup>®</sup> and Cempanel<sup>®</sup>** panel siding is nominal  $\frac{5}{16}$ " thick. The siding is 4 feet wide and comes in lengths of 8, 9, and 10 feet.

**Hardiplank<sup>®</sup>, Complank<sup>®</sup>, Sentry<sup>™</sup>, and Hardishingle<sup>™</sup>** lap siding is nominal  $\frac{5}{16}$ " thick. The siding comes in 12 foot lengths. The siding is available in widths up to 12 inches. The siding is available in smooth and woodgrain finishes.

**Hardishingle<sup>™</sup>** cladding shingles are nominal  $\frac{1}{4}$ " thick. The siding comes in dimensions of 6", 8", and 12" wide x 18" long. When installed, the cladding has the appearance of wood shingles. The cladding has an 8" exposure.

**Hardishingle<sup>™</sup>** panel cladding is nominal  $\frac{1}{4}$ " thick. The siding has dimensions of 48" wide x 19" or 16" long. When installed, the cladding has an appearance of wood shingles. The cladding has a 7" exposure. The cladding is available in half round, staggered edge and straight edge panels.

## INSTALLATION REQUIREMENTS

### General Installation Requirements:

All fasteners shall be corrosion resistant.

**Hardiplank®**, **Cemplank®**, **Hardipanel®**, and **Cempanel®** siding: The siding may be installed over structural sheathing if it is nailed through the sheathing and into the framing members. If the siding is installed over non-structural sheathing (foam, gypsum board, fiberboard), then the length of the fastener used to secure the siding to the wall framing shall be increased by the thickness of the non-structural sheathing.

**Hardiplank®** and **Cemplank®** siding: Vertical splices shall be made between framing members using an off-stud metal joiner or over a framing member. If the vertical splice occurs over a framing member, then the fastener shall be between  $\frac{3}{8}$  inch and  $\frac{1}{2}$  inch from the vertical splice and between  $\frac{3}{4}$  inch and 1 inch from the edge of the siding. When using an off-stud metal joiner, splices shall be located at least two stud cavities from the wall corner and one stud cavity away from door or window openings. In addition, successive splices in the same plank shall be at least 48 inches apart and splices within the same stud cavity shall be at least 24 inches apart.

**Hardishingle™** cladding shingles: The cladding shingles shall be installed directly to wood structural panels.

**Hardiplank®**, **Cemplank®**, **Sentry™**, and **Hardishingle™** lap siding, **Hardishingle™** cladding shingles, and **Hardishingle™** panels: These products shall not be used as wall bracing.

### Wind Resistant Assemblies:

#### Assembly No. 1

**Hardiplank®**, **Cemplank®**, **Sentry™**, and **Hardishingle™** Lap Siding (Exposed Nailing Method)  
Design pressure: -38 psf

**Installation:** Wall studs shall be minimum Southern Pine dimension lumber spaced a maximum of 16 inches on center. If 2x6 lumber is used, then the wall studs may be spaced 24 inches on center. Wall bracing shall be installed as required. A building paper shall be applied to the wall studs before installing the siding. The siding shall be fastened to the wall studs with minimum 6d galvanized common wire nails using the exposed nailing method. The first **Hardiplank®** or **Cemplank®** should be installed horizontally over a  $\frac{1}{4}$  inch wide weather resistant lath starter strip. Fasteners should be located approximately  $\frac{5}{8}$  inch from the bottom of the plank. The remaining courses are then installed with minimum  $1\frac{1}{4}$  inch wide overlaps. Flashing, trim, and corners should be installed according to the manufacturer's specifications.

The following products are applicable: Lap siding 12 inches in width.

#### Assembly No. 2

**Hardiplank®**, **Cemplank®** Lap Siding (Concealed Nailing Method)  
Design pressure: -49 psf

### **Assembly No. 2 (Continued)**

**Installation:** Wall studs shall be minimum 2x4 SPF dimension lumber spaced a maximum of 16 inches on center. Wall bracing shall be installed as required. A building paper shall be applied to the wall studs before installing the siding. The siding shall be fastened to the wall studs with minimum 11 gauge galvanized roofing nails (1 $\frac{3}{4}$  inch long,  $\frac{3}{8}$  inch diameter head). The fasteners shall be driven through the top of the plank and into the framing member. The fastener should be between  $\frac{3}{4}$  inch and 1 inch from the top edge of the plank and covered by the next succeeding course of planks. The first Hardiplank® or Cemplank® should be installed horizontally over a  $\frac{1}{4}$  inch wide weather resistant lath starter strip. The remaining courses are then installed with minimum 1 $\frac{1}{4}$  inch wide overlaps. Flashing, trim, and corners should be installed according to the manufacturer's specifications.

**The following products are applicable:** Lap siding 9 $\frac{1}{2}$  inches in width or less.

### **Assembly No. 3**

#### **Hardiplank®, Cemplank® Lap Siding (Concealed Nailing Method)**

**Design pressure:** -44 psf

**Installation:** Wall studs shall be minimum 2x4 SPF dimension lumber spaced a maximum of 16 inches on center. Wall bracing shall be installed as required. A building paper shall be applied to the wall studs before installing the siding. The siding shall be fastened to the wall studs with galvanized fasteners with the following minimum dimensions: 0.113 inch shank diameter, 2.014 inch long, and 0.274 inch diameter head. The fasteners shall be driven through the top of the plank and into the framing member. The fastener should be between  $\frac{3}{4}$  inch and 1 inch from the top edge of the plank and covered by the next succeeding course of planks. The first Hardiplank® or Cemplank® should be installed horizontally over a  $\frac{1}{4}$  inch wide weather resistant lath starter strip. The remaining courses are then installed with minimum 1 $\frac{1}{4}$  inch wide overlaps. Flashing, trim, and corners should be installed according to the manufacturer's specifications.

**The following products are applicable:** Lap siding 8 $\frac{1}{4}$  inches in width or less.

### **Assemblies No. 4 and No. 5**

#### **Hardiplank®, Cemplank®, Sentry™, and Hardishingle™ Lap Siding (Exposed Nailing Method)**

##### **Assembly No. 4**

**Design pressure (6d common wire nails):** -66 psf

##### **Assembly No. 5**

**Design pressure (0.089 inch shank, 2.131 inch long, 0.221 inch head):** -53 psf

**Installation:** Wall studs shall be minimum 2x4 SPF dimension lumber spaced a maximum of 16 inches on center. Wall bracing shall be installed as required. A building paper shall be applied to the wall studs before installing the siding. The siding shall be fastened to the wall studs using the exposed nailing method. The fasteners should be located approximately  $\frac{5}{8}$  inch from the bottom of the plank. The first Hardiplank® or Cemplank® should be installed horizontally over a  $\frac{1}{4}$  inch wide weather resistant lath starter strip. The remaining courses are then installed with minimum 1 $\frac{1}{4}$  inch wide overlaps. Flashing, trim, and corners should be installed according to the manufacturer's specifications.

**The following products are applicable:** Lap siding 9 $\frac{1}{2}$  inches in width or less.

### Assembly No. 6

#### Hardishingle™ cladding shingle (Concealed Nailing Method)

**Design pressure:** -45 psf

**Fastener:** 0.091" shank diameter, 2.473" long, and 0.221" diameter head

**Installation:** Wall studs shall be minimum 2x4 SPF dimension lumber spaced a maximum of 16 inches on center. Wall bracing shall be installed as required. The walls shall be fully sheathed with minimum  $\frac{7}{16}$ " wood structural panels. A building paper shall be applied to the walls before installing the cladding. The fasteners shall be installed nominally 1" from each edge and at the midpoint of the shingle. The fasteners shall be located approximately 9" from the exposed edge. The first course of cladding should be installed as the starter course consisting of shingles inverted and laid horizontal. Flashing, trim, and corners should be installed according to the manufacturer's specifications.

### Assembly No. 7

#### Hardishingle™ cladding shingle (Concealed Nailing Method)

**Design pressure:** -50 psf

**Fastener:** 0.121" shank diameter,  $1\frac{1}{4}$ " long, and  $\frac{3}{8}$ " diameter head

**Installation:** Wall studs shall be minimum 2x4 SPF dimension lumber spaced a maximum of 16 inches on center. Wall bracing shall be installed as required. The walls shall be fully sheathed with minimum  $\frac{7}{16}$ " wood structural panels. A building paper shall be applied to the walls before installing the siding. The cladding shall be fastened to the wall sheathing with galvanized fasteners with the following minimum dimensions: 0.121" shank diameter,  $1\frac{1}{4}$ " long, and  $\frac{3}{8}$ " diameter head. The fasteners shall be installed nominally 1" from each edge and located approximately 9" from the exposed edge. The first course of cladding should be installed as the starter course consisting of shingles inverted and laid horizontal. Flashing, trim, and corners should be installed according to the manufacturer's specifications.

### Assembly No. 8

#### Hardishingle™ panel cladding

**Design pressure:** -31 psf

**Fastener:** 0.083" shank diameter,  $1\frac{1}{2}$ " long, and 0.187" diameter head

**Installation:** The walls shall be fully sheathed with minimum  $\frac{7}{16}$ " wood structural panels. A building paper shall be applied to the walls before installing the siding. The cladding shall be fastened to the wall sheathing with fasteners spaced  $13\frac{3}{4}$ " horizontally. The fasteners are located nominally  $\frac{1}{2}$ " from each edge and approximately 8" from the exposed edge. For the staggered installation mode, the fasteners are covered by 1" of the overlapping panel, and the fasteners are exposed for the straight installation mode. A  $\frac{1}{4}$ " thick minimum  $9\frac{1}{4}$ " Hardiplank or Cemplank lap siding lath shall be installed as the starter course to set the proper slope. Flashing, trim, and corners should be installed according to the manufacturer's specifications.

### Assembly No. 9

#### Hardishingle™ panel cladding

**Design pressure:** -61 psf

**Fastener:** 0.083" shank diameter,  $1\frac{1}{2}$ " long, and 0.187" diameter head

### Assembly No. 9 (Continued)

**Installation:** Wall studs shall be minimum 2x4 SPF dimension lumber spaced a maximum of 16 inches on center. A building paper shall be applied to the walls before installing the siding. The cladding shall be fastened to the wall studs spaced 16" on center. The fasteners shall be installed nominally  $\frac{1}{2}$ " from each edge and located approximately 8" from the exposed edge,  $\frac{3}{4}$ " above the  $\frac{1}{4}$ " wide keyway. Flashing, trim, and corners should be installed according to the manufacturer's specifications.

### Assembly No. 10

#### Hardishingle™ panel cladding

**Design pressure:** -49 psf

**Fastener:** 0.083" shank diameter,  $1\frac{1}{2}$ " long, and 0.187" diameter head ring shank

**Installation:** Wall studs shall be minimum 2x4 SPF dimension lumber spaced a maximum of 24 inches on center. A building paper shall be applied to the walls before installing the siding. The cladding shall be fastened to the wall studs spaced 24" on center. The fasteners shall be installed nominally  $\frac{1}{2}$ " from each edge and located approximately 8" from the exposed edge,  $\frac{3}{4}$ " above the  $\frac{1}{4}$ " wide keyway. Flashing, trim, and corners should be installed according to the manufacturer's specifications.

### Assemblies No. 11 and No. 12

#### Hardipanel®, Cempanel® Panel Siding

**Assembly No. 11 (wall studs 16 inches on center)**

**Fasteners:** 6d common wire; 6" on center along panel edges and along intermediate framing

**Design pressure:** -75 psf

**Racking load resistance of siding:** 302 plf

**Assembly No. 12 (wall studs 24 inches on center)**

**Fasteners:** 6d common wire; 4" on center along panel edges and along intermediate framing

**Design pressure:** -72 psf

**Racking load resistance of siding:** 318 plf

**Installation (general):** Wall studs shall be minimum SPF dimension lumber. Wall bracing shall be installed as required. A building paper shall be applied to the wall studs before installing the siding. The panel siding shall be installed vertically with all joints occurring over framing members. The fasteners shall be spaced no closer than  $\frac{3}{8}$  inch from the edge and no closer than 2 inches from the corner.

**Installation (when used as wall bracing):** Wall studs shall be minimum Stud or No. 3 grade SPF dimension lumber. The panels shall be installed with the long dimension in the vertical direction. Each siding panel used as wall bracing shall be a minimum of 48 inches in width. The fasteners shall penetrate the wall studs a minimum of  $1\frac{1}{2}$  inches. The siding shall be fastened to the upper member of the double top plate and to the sole plate. All panel edges shall be nailed to wall framing.

**Note:** The manufacturer's installation instructions shall be on the job site during the installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC) and the International Building Code (IBC).